

STAKE HOLDER CONSULTATION PROCESS OFFSHORE GRID NL	
Type:	Feedback report
Work stream	Technical
Topics:	O.2 Stranded asset mitigation
Filename	ONL 15-136 O2_Stranded asset mitigation_FBRe_v1
Version	1 – final for publication
Pages	2

QUALITY CONTROL		
Prepared:	Anna Ritzen	
Reviewed:	Michiel Müller	03.06.2015
Approved:	TenneT	19.06.2015
Release	Public	

Table of Contents

1. EXPERT MEETING 27.11.2014	2
2. EXPERT MEETING 29.01.2015	2
3. EXPERT MEETING 18.03.2015	2
4. EXPERT MEETING 15/16.04.2015	2
<i>Summary of concerns based on feedback during the Expert Meeting</i>	<i>2</i>
5. EXPERT MEETING 12/13.05.2015	2
6. TENNET STAKEHOLDER CONSULTATION WEBSITE APRIL	2
7. BI-LATERAL MEETINGS	2
8. OTHER	2

1. Expert Meeting 27.11.2014

n/a

2. Expert Meeting 29.01.2015

n/a

3. Expert Meeting 18.03.2015

n/a

4. Expert Meeting 15/16.04.2015

Summary of concerns based on feedback during the Expert Meeting

- Please also include the risk that the wind turbines will not be energised during the operational phase

5. Expert Meeting 12/13.05.2015

n/a

6. TenneT stakeholder consultation website April

No generators are foreseen to support power to WTG in case on grid outage, TenneT intends to install 66kV-link between two platforms could reduce the risk of power outage, nevertheless the bottlenecks for a grid outage need to be investigated. A longer outage of power supply can cause high costs or/and damages on WTGs. In case cable to shore is delayed power supply from platform should be provided to avoid delays at WTG commissioning.

7. Bi-lateral meetings

n/a

8. Other