

STAKE HOLDER CONSULTATION PROCESS OFFSHORE GRID NL	
Type:	Feedback Follow-Up
Work stream	Technical
Topics:	T.11 Overplanting
Filename	ONL 15-181 T11_Overplanting_FFU_v1
Version	1 - public release
Pages	2

QUALITY CONTROL	
Prepared:	Barry Vree
Reviewed:	Michiel Müller
Approved:	TenneT, Rob van der Hage
Release	Public

Table of Contents

1. CONSULTATION FEEDBACK.....	2
2. FEEDBACK FOLLOW-UP AND NEXT STEPS	2

1. Consultation feedback

The topic of dynamic loading of the export system has been discussed with stakeholders for the first time during the Expert Meeting of 15-16.04.2015. In addition, market feedback on the topic has been collected through the stakeholder engagement website of TenneT. The feedback on the topic can be summarised as follows:

- **Consensus.** There is a general consensus that every party will consider whether or not overplanting / dynamic loading will be incorporated in the design of the wind farm. For this the parties require clear boundary conditions provided by TenneT, as well as any information available on cable design and soil conditions to evaluate dynamic loading possibilities.
 - Mitigation/Follow-up: TenneT intends to provide basic assumptions used in the dynamic loading calculations and provide updates when more information becomes available.

2. Feedback follow-up and next steps

Based on the internal evaluation, external reports and collected feedback during the stakeholder engagement process the following has been decided:

TenneT's position on 'T11 Overplanting':

TenneT intends allowing the PPMs to transmit 10% above their rated power (350MW), which is 35MW extra, with the requirement for PPM's to curtail their produced power, in case the 220 kV export cables reach their maximum allowable temperature limits¹. Details on curtailment of the PPMs will be addressed to in the 'Customer Connection Agreements (ATO)'.

Is ready for final decision making by the appropriate body and will not come back in the stakeholder consultation process.

¹ Operational limits of sea and land cables will be monitored continuously by temperature sensing systems.