

STAKE HOLDER CONSULTATION PROCESS OFFSHORE GRID NL	
Type:	Feedback report
Work stream	Technical
Topics:	T18_Data acquisition systems on offshore platform
Filename	ONL-TTB-03079 T18_Data acquisition systems on offshore platform_FBRe_v1.docx
Version	1 – public release
Pages	4

QUALITY CONTROL		
Prepared:	Barry Vree	17.11.2015
Reviewed:	Michiel Müller	17.11.2015
Approved:	Frank Wester	25.11.2015
Release	Public	

Table of Contents

1. MOMENTS OF FEEDBACK	2
2. FEEDBACK AND ACTION	2

1. Moments of feedback

Feedback	Abbreviation
Expert meeting 27.11.2014	EM01
Expert meeting 29.01.2015	EM02
Expert meeting 18.03.2015	EM03
Expert meeting 15&16.04.2015	EM04
Expert meeting 12&13.05.2015	EM05
Consultation website March	WS01
Consultation website April	WS02
Consultation website May	WS03
Consultation website June	WS04
Consultation website November	WS09
Bi-lateral meetings	BL01

2. Feedback and action

Feedback	Feedback moment	Action
<p>Cost best at the account of TenneT/RWS. Inefficient to have these costs at the account of the WPO because: The WPO is not the party best able to asses those costs. Therefore this leads to an inaccurate figure represented in the bid O Offers need to be asked by all bidding parties for equipment that will never be ordered. Parties know this and offers are likely to be inaccurate. O Unknown what the costs are of RWS maintaining and operating the equipment O Unknown between how many parties these costs are split</p>	WS09	Feedback was received after closing date of the topic. See "ONL-TTB-03103 T18_Data acquisition systems on offshore platform_PP_v2".
CCTV needs to be separate as well because of control camera's	WS09	Feedback was received after closing date of the topic. See "ONL-TTB-03103 T18_Data acquisition systems on offshore platform_PP_v2".
LIDAR can be shared, as long as there is also opportunity to install a lidar by WPO if required by WPO	WS09	Feedback was received after

		closing date of the topic. See “ONL-TTB-03103 T18_Data acquisition systems on offshore platform_PP_v2”.
DTS TenneT needs to be shared for overplanting, important information, and we need to know whether this will be available when we hand in a bid in order to allow overplanting.	WS09	Feedback was received after closing date of the topic. See “ONL-TTB-03103 T18_Data acquisition systems on offshore platform_PP_v2”.
Ship radar needs to be available in case the policy changes and ships are allowed sail through wind farm.	WS09	Feedback was received after closing date of the topic. See “ONL-TTB-03103 T18_Data acquisition systems on offshore platform_PP_v2”.
UMTS is preferable as well.	WS09	Feedback was received after closing date of the topic. See “ONL-TTB-03103 T18_Data acquisition systems on offshore platform_PP_v2”.
Annex P.5 - Where will the interface cabinet with CT/VT's be placed? (expected in room designated for connected party).	WS09	Feedback was received after closing date of the topic. See “ONL-TTB-03103 T18_Data acquisition systems

		on offshore platform_PP_v2".
--	--	------------------------------

Other feedback related to the legal agreements are treated in the legal topics Q&A table.